

Power System Protection Schemes for the Integration of Renewable, Inverter-Based Generation: A Review of Fault Behaviour, Maloperation, and Emerging Countermeasures

Azain Qadir

Department of Electrical Engineering, Government College University Faisalabad
Email: azainqadir456@gmail.com

Azeem Asghar

Department of Electrical Engineering, University of Engineering and Technology
Taxila Email: azeemasghar476@gmail.com

Muhammad Faisal Shaheryaar

Department of Mechatronics and Control Engineering, University of Engineering and Technology Lahore Email: Faisalshaheryaar@gmail.com

Syed Alamdar Ul Hasnain Naqvi

Department of Electrical Engineering, Government College University, Faisalabad
Email: alamdarsyed005@gmail.com

ABSTRACT

For more than a century, the protective relaying of electric power systems has been built on a single, dependable assumption: that a fault draws a large, briefly sustained burst of current from a synchronous machine. Wind, solar and battery plants overturn that assumption. Because they reach the grid through power-electronic inverters rather than spinning machines, they feed a fault with a current that is small, fast to settle, and shaped by control software rather than by machine physics. This review examines what that shift does to protection and what the recent engineering literature proposes to do about it. It revisits the fundamentals of overcurrent, distance and differential relaying and the physics of the fault-current transient, then contrasts the two dominant inverter control modes, grid-following and grid-forming, each of which leaves a different short-circuit signature. Against that background it collects the documented failure modes, distance-relay under-reach, overcurrent elements that never pick up, and mistimed coordination between wind-farm collector systems and the transmission network, and the families of countermeasure advanced to address them: adaptive settings, wide-area protection built on synchrophasors, and distributed multi-agent schemes. Protection of inverter-dominated microgrids and of voltage-source-converter HVDC links is treated separately, because both push still further from classical practice. The review closes with the economics and standardisation of the transition, centred on IEEE Standard 2800-2022, and with a set of recommendations for a protection architecture fit for a grid whose fault current is increasingly defined by control code. A recurring theme is that the binding constraints are now as much about

communication, validation and standardisation as about relay settings.

Keywords: Power System Protection; Inverter-Based Resources; Fault Current; Distance Relay; Adaptive Protection; Renewable Energy Integration; IEEE 2800-2022

Introduction

Protective relaying grew up around the synchronous generator. For a hundred years the generator was, in effect, the only source of fault current that mattered, and its behaviour was reassuringly predictable. Short a transmission or distribution line and a synchronous machine drives a large, well-characterised current into the fault, on the order of five to ten times its rated value, which then decays through recognisable subtransient, transient and steady-state phases. The whole apparatus of protection, from a plain overcurrent relay to a coordinated distance and differential scheme, was designed and set against that behaviour (Haddadi et al., 2021). Over the past two decades, however, wind and solar plant interfaced through power electronics has taken an increasing share of generation, and on many systems the character of the fault current has changed with it.

An inverter does not produce fault current the way a rotating machine does. Its control loops are fast and digital, and the current it can push into a fault is capped only slightly above its rated value by the thermal limits of its semiconductors, rather than reaching the high multiples a synchronous source delivers (Haddadi et al., 2021). That single difference propagates into a whole family of protection problems: distance elements that under-reach, overcurrent elements that never pick up, and coordination that slips between a wind farm's collector protection and the transmission line beyond it (Quispe & Orduña, 2022). Because inverter-based resources are a rising share of installed capacity worldwide, this is no longer a matter of nudging a few relay settings; it is a design problem for the protection engineer.

What raises the stakes is that protection is the last line of defence. It is what stops a fault from becoming equipment damage, a fire, or a cascading outage, and in a period of heavy renewable output a single maloperation can pull down far more of the network than the original fault would have. Several large disturbances on systems with high inverter penetration have involved protection that operated, or failed to operate, in ways its designers did not intend, and a number of transmission operators have consequently moved protection redesign from the study pile to the operational priority list (Quispe & Orduña, 2022).

This review works the problem from the ground up. It begins with the fundamentals of conventional protection and the circuit physics of a fault, because that is what makes clear why inverters behave so differently. It then sketches the shift in the generation mix, separates inverter control into its grid-following and grid-forming forms, and sets out the specific protection problems that inverter-based resources create together with the adaptive, wide-area and communication-assisted answers proposed in recent work. Microgrids and voltage-source-converter HVDC are handled in their own sections, because their fault behaviour departs even further from classical assumptions. The review ends with the economics and standardisation of the transition, IEEE Standard 2800-2022 in particular, and a set of recommendations for a

renewable-ready protection architecture.

Two contributions distinguish this review from the several competent single-topic surveys already in print. First, it reads the transmission, distribution, wind-farm, microgrid and HVDC literatures against one another rather than in isolation, which brings out failure modes and countermeasures that recur across domains. Second, it maps where the literature is mature and where it is thin, and that gap analysis, summarised in Figure 5, is used to frame the recommendations rather than being left implicit.

Fundamentals of Power System Protection

Protection philosophy and relay types

The purpose of protection is narrow and unforgiving: detect an abnormal condition and disconnect the smallest possible part of the network in the shortest possible time, so that damage is contained and the rest of the system rides through. Three properties are asked of any scheme. It must be selective, isolating only the faulted element; it must be fast, so that fault energy and mechanical stress are limited; and it must be dependable, operating when it should and staying still when it should not. These aims are met with a handful of complementary relay types, each matched to a part of the network and a fault signature.

The oldest and simplest are overcurrent relays, which trip after a set time once the current they see exceeds a threshold. A distance relay instead measures the ratio of voltage to current at a bus, uses it to estimate the electrical distance to the fault, and so protects a line without needing information from the remote end. Differential relays compare the current entering and leaving a protected zone, a transformer or a short line, and trip when the two fail to balance by more than load and measurement error can explain. Every one of these families was developed, tuned and coordinated on the assumption that fault current comes chiefly from synchronous machines, which is exactly why they struggle when it does not (Haddadi et al., 2021).

Overcurrent, distance and differential protection in practice

On transmission and subtransmission networks distance protection dominates, because it does not need to know the exact magnitude of the fault current and works from the apparent impedance seen at the relay. A distance relay is normally set with several reach zones: an instantaneous first zone covering roughly the first eighty per cent of the line, and one or more time-delayed zones reaching into adjacent lines to provide backup. This zoning gives both speed and inherent backup, but it leans on two assumptions, that the fault current is large enough to measure cleanly, and that the phase relationship between voltage and current is close enough to the expected value for the impedance estimate to be trusted.

Differential protection is far less troubled by the magnitude of the fault current, because it compares currents against each other rather than against a fixed threshold, which makes it comparatively robust where inverters dominate. Overcurrent protection sits at the other extreme, depending directly on the magnitude of the fault current, and it turns out to be the most vulnerable scheme of all when a source limits its own fault contribution, a point made repeatedly in studies of inverter-based interconnection (Quispe & Orduña, 2022; Haddadi et al., 2021).

The physics of fault current: transient, DC offset and the X/R ratio

The shape of a fault current follows directly from the physics of an inductor-resistor circuit suddenly energised, which is a fair model of a transmission line and generator winding at the instant of a short circuit. Before the fault the circuit carries a modest load current; at the instant of the fault the equivalent impedance collapses, and the current must climb from its pre-fault value to a much larger steady-state value. Because the line behaves as an inductor, that climb cannot be instantaneous, and the current rises exponentially toward its new value.

Two familiar features follow. The first is the DC offset, an asymmetry superimposed on the sinusoidal current; the second is the multi-stage decay of the symmetrical current as the machine's flux linkages settle. The offset is largest when the fault strikes at a voltage zero crossing and lasts longest when the ratio of circuit reactance to resistance, the X/R ratio, is high. A high X/R ratio, typical of large transformers and long lines, can hold an offset of several hundred amperes for more than a second, and the symmetrical current decays over a comparable interval.

This matters because every conventional protection setting, every published table of fault current, and every coordination study rests on it. When a relay engineer computes a distance reach or an overcurrent pickup, the calculation assumes a fault current with this subtransient-to-steady decay and a magnitude several times rated. Inverter-based resources dissolve that assumption. A power-electronic converter stores and releases almost no magnetic energy; it sets its maximum output as a digital control target within a fraction of a cycle, and the result bears little resemblance to the classical RL transient (Haddadi et al., 2021).

It is worth being precise about what has and has not changed. The laws of the circuit are untouched: the RL transient still governs the electromagnetic environment the inverter sits in, and the network downstream keeps its own X/R ratio and its own transient response. What changes is the driving source. A synchronous machine answers a fault passively, through its own flux field; a converter is an active, digitally controlled source that can be programmed to respond in almost any way the grid code and the manufacturer choose, whether as a current-limited source, a voltage-supporting one, or something in between.

The Changing Generation Landscape

The rise of inverter-based generation

In fifteen years renewables have gone from a fringe of installed capacity to the bulk of new build in many markets, driven by falling technology costs, supportive policy and decarbonisation commitments. Almost all of this new capacity reaches the grid through power-electronic inverters rather than directly coupled synchronous machines, and it is convenient to group it under the single label of inverter-based resources. Battery energy storage, itself inverter-interfaced, adds a further layer of power-electronic generation, and of protection-relevant behaviour, to the network (Davi et al., 2023).

For the protection engineer the consequence is that whole stretches of some transmission systems now see fault current that is inverter-dominated rather than synchronous, especially when renewable output is high and conventional plant is backed off. Several studies have found protection performance to be sensitive to

exactly these high-penetration, low-inertia conditions, because both the magnitude and the waveform of the available fault current shift with the generation mix that happens to be online at the instant of the fault (Quispe & Orduña, 2022; Rezaei Jegarluei et al., 2023).

This is a real break with past practice. When an engineer sized protection for a bus decades ago, it was reasonable to treat the fault current there as lying within a fairly narrow band, because the sources feeding it changed slowly and were overwhelmingly synchronous machines with well-known impedances. On a modern system the same bus may see markedly different fault current on a windy night than on a still summer evening, purely because the mix of synchronous and inverter sources online has changed. A setting chosen for a typical case can end up over- or under-sensitised depending on which case is actually in play when the fault occurs.

Grid-following versus grid-forming inverters

An inverter's fault response is decided by its control strategy, and two broad families dominate today. The conventional choice for wind and solar farms is the grid-following inverter, which takes the grid voltage as an external reference and holds its output current to the commanded value, behaving in effect as a controlled current source. During a fault it clamps its output only modestly above rated current, both to protect its semiconductors and because its synchronising loop struggles when the grid voltage collapses toward zero (Johansson et al., 2025).

The alternative is to build an internal voltage reference and emulate, more closely, a voltage source, which is what a grid-forming inverter does. This lets it deliver a larger and faster fault current and offer some voltage support during a disturbance, though still within a current limit far below that of a comparable synchronous machine. The distinction matters directly for protection: distance relays have been shown to respond differently to grid-following and grid-forming sources, because the two trace different transient impedance trajectories at the relay (Johansson et al., 2025).

Protection Challenges from Inverter-Based Resources

Reduced and distorted fault current

The first and largest difference is simply how much current is available. A synchronous generator can drive five to ten times its rated current into a nearby fault; a grid-following inverter is typically held to between one and one-and-a-half times rated, and even a grid-forming inverter to roughly twice. Magnitude is not the whole story. Even where the inverter output stays close to the clean sinusoid that relay algorithms expect, those algorithms also assume the fault leaves the system voltage largely intact, whereas control-loop behaviour and current-limiting logic distort the actual output during the fault.

These features degrade protection in several ways at once. An overcurrent relay set to a high multiple of load current may never operate on an inverter-fed fault, because the fault current simply never reaches the pickup threshold. Negative- and zero-sequence elements can be blinded too, since many grid-following inverters are designed not to inject negative-sequence current, denying the relay the very signal its logic was built to detect (Haddadi et al., 2021; Mobashsher et al., 2023). Figure 1 makes the pickup problem concrete: a threshold chosen for synchronous infeed can sit above the entire

fault-current contribution an inverter is able to provide.





Figure 1. Why a fixed overcurrent pickup can miss inverter-fed faults. A pickup threshold chosen for synchronous infeed (dashed line) exceeds the fault current an inverter-based resource can supply, so the element never operates. Illustrative magnitudes after Haddadi et al. (2021) and IEEE Std 2800-2022.

Distance-relay maloperation and adaptive countermeasures

Distance protection is especially exposed, because its impedance calculation depends on a fault current of a particular magnitude and a particular phase relationship to the pre-fault voltage. The controlled, phase-shifted current an inverter injects can push the measured impedance away from its true value, producing over- or under-reach. Under-reach is the dangerous case: an in-zone fault is read as lying outside the relay's reach and is not cleared promptly. Figure 2 shows the mechanism on the R–X plane. Mobashsher et al. (2023) proposed an accelerated distance scheme that resists under-reach on inverter-connected lines by reconstructing the impedance calculation.

Distance-relay under-reach on the R–X plane



Current-limited, phase-shifted IBR infeed inflates the measured impedance, so an in-zone fault is read as out-of-zone.

Figure 2. Distance-relay under-reach on the R–X plane. Current-limited, phase-

shifted infeed from an inverter-based resource inflates the impedance the relay measures, so a fault at 60 per cent of the line is read as lying outside the instantaneous Zone 1 and clears only on a delayed backup zone.

Wind farms sharpen the problem. For lines joining two doubly-fed induction generator (DFIG) wind farms, the mix of partial power-electronic control and induction-machine behaviour produces a distinctive fault signature, and Shahbazzadeh et al. (2025) set out adaptive logic and a pair of coordination techniques to keep distance relays working reliably in that setting. Barati et al. (2021) examined the further complication of a collector line compensated by a static synchronous compensator, and found that flexible AC transmission system devices can distort the impedance point a distance relay sees still further.

Wind-farm collector systems and transmission coordination

Beyond how a wind farm interacts with the transmission grid lies the problem of protecting the farm itself. A wind farm is usually a string of hundreds of turbines linked by a radial or looped medium-voltage collector system into a collector substation and thence to the grid. Fault ride-through requirements, which keep turbines connected and injecting limited current during a nearby fault, bear directly on coordination, because a turbine that remains connected with a rotor-side short behaves quite unlike one that has tripped or a synchronous machine delivering full fault current. Yoosefian et al. (2023) tackled this directly, proposing a protection scheme for distribution systems with wind farms that builds the ride-through constraint in rather than assuming it away.

Table 1 draws the three source types together on the characteristics that matter most for protection. The contrast in the first two rows, fault-current magnitude and its decay behaviour, is the root of nearly every problem discussed in this section.

Table 1. Fault-response characteristics of the three principal generation source types.

Characteristic	Synchronous generator	Grid-following IBR	Grid-forming IBR
Typical fault-current magnitude	5–10× rated (subtransient)	1.0–1.5× rated, current-limited	~2× rated, current-limited
Fault-current decay	Exponential subtransient / transient / steady-state decay	Rapid transition to a controller-limited steady value	Near-instantaneous limit, faster than grid-following
Negative-sequence support	Inherent, set by machine impedance	Limited; depends on manufacturer control	Configurable; generally closer to synchronous behaviour
Voltage behaviour during fault	Internal EMF largely maintained	Follows depressed grid voltage	Actively supports voltage within current limit
Principal relay impact	Assumptions embedded in legacy overcurrent and distance settings	Distance under-reach; possible overcurrent non-pickup	Improved but still current-limited relative to synchronous

Note. Compiled from characteristics reported by Haddadi et al. (2021), Johansson et al. (2025) and IEEE Std 2800-2022.

Validating any proposed fix usually takes more than a steady-state study, because these effects play out over a handful of inverter cycles and the control-loop physics contribute in ways simplified models miss. Real-time digital simulation, which runs detailed inverter control models fast enough to drive real relay hardware in a closed loop, has become the common proving ground for this body of work, letting an adaptive or accelerated scheme be tested against realistic controls before any field trial. It is also a practical brake on adoption, since it demands dedicated laboratory facilities and close cooperation between protection engineers and inverter manufacturers, who may be reluctant to reveal proprietary control algorithms.

Emerging Protection Solutions

The countermeasures proposed in the literature fall into a small number of families, shown together in Figure 3. They are not mutually exclusive; a practical installation may combine adaptive local settings with a wide-area backup layer.




Figure 3. A taxonomy of protection solutions for inverter-dominated grids, with representative studies. The four families are complementary rather than competing, and real installations often layer them.

Adaptive protection

Adaptive schemes change their relay settings automatically according to the operating state of the system, instead of holding a single fixed value derived from a worst case. This suits inverter-dominated systems well, because the fault current available at a given point can vary widely with the sources online at the moment of the fault, so a setting computed for one condition will not serve another. Adaptive schemes recompute settings, or select among pre-computed setting groups, using the current topology and generation status, restoring sensitivity and selectivity across a far wider range of operating conditions (Mobashsher et al., 2023; Barati et al., 2021).

Wide-area protection with synchrophasors

Wide-area protection extends the adaptive idea by drawing on measurements from across the network rather than from one relay. Its sensing rests on the phasor measurement unit, which reports time-synchronised voltage and current phasors at high sampling rates, and on the wide-area monitoring systems that turn those data into system-wide situational awareness. Because a wide-area scheme reasons from a data source that does not depend on the local generation mix, it is inherently more robust to the fault-current variation that troubles local relays (Phadke & Bi, 2018).

Rezaei Jegarluei et al. (2023) set out a wide-area backup protection scheme for asymmetrical faults on renewable-rich systems, noting that backup schemes reasoning from current and impedance, exactly as primary protection does, are especially vulnerable to inverter penetration and stand to gain most from a wide-area view. The catch is dependence on communication: because these schemes require uninterrupted, low-latency links, their dependability is tied to the communications system behind them, a requirement local relays never carried and one that demands real design discipline.

Multi-agent and communication-assisted protection

A related line of work builds protection from multi-agent systems, in which separate intelligent agents each watch a small part of the network and coordinate with their neighbours to settle on a local strategy. Peidaee et al. (2020) coupled a heuristic multi-agent protection system to a distribution network with distributed energy resources and showed that the agents' negotiation preserved selective protection as the size and location of small inverter sources changed. A population of small, relatively simple local devices scales in a way that a centralised wide-area scheme cannot, since new devices can be added as the system grows without rebuilding the protection logic wholesale.

The physical root of every problem and every solution in this section is the same, and Figure 4 states it directly: the current-limited fault contribution of inverter-based resources, whether grid-following or grid-forming, set against the large decaying contribution of a synchronous machine. Everything downstream, the under-reach, the pickup failures, the adaptive and wide-area fixes, follows from that one contrast.




Figure 4. Idealised short-circuit current signatures by generation source. A synchronous machine delivers a large current with a decaying envelope and DC

offset; a grid-following inverter clamps to little above rated current; a grid-forming inverter reaches roughly twice rated with a faster limit and some voltage support. After Haddadi et al. (2021).

Microgrid Protection

Microgrids are hard to protect because they run in two modes with very different levels of available fault current and, often, a different dominant source in each. A scheme designed for grid-connected operation, with substantial fault current arriving from the upstream utility, may be useless once the microgrid islands and only its inverter-based sources remain to feed a fault. Since the change between grid-connected and islanded operation can happen automatically and fast, static settings have generally been judged unsuitable for microgrids (Hussain et al., 2021).

Two studies illustrate the response. The study by dos Reis et al. (2021) proposed a dual-strategy multi-agent adaptive design that explicitly reconfigures relay settings as the microgrid moves between grid-connected and islanded states, reporting better fault detection in both modes than fixed settings achieved. Hussain et al. (2021) took a communication-centred route, using continuous inter-relay communication to hold selective coordination as the available fault current varied. Both arrive at the same conclusion: microgrid protection needs some knowledge of the operating mode and the sources available, rather than a single assumed level of fault current.

This is also where a magnitude-independent principle pays off. A balance of the instantaneous line currents, as in differential protection, does not care how large the fault current is, which is precisely the property a microgrid needs. Several of the adaptive schemes above are therefore two-element designs, pairing a directional or overcurrent element for security with a differential element for speed.

Islanding detection is a closely related second function, because a scheme must first know that a transition to islanded operation has occurred before it can apply the right mode-specific settings. Passive methods, keyed to voltage and frequency deviation at the point of common coupling, can be slow, or can false-trip when generation and load happen to be well matched at the moment of separation, which has driven the development of active and communication-assisted detection that can confirm a trip more quickly and reliably. The quality of this step caps everything downstream: an adaptive scheme cannot apply mode-specific settings while it is still unsure which mode it is in.

HVDC and Multi-Terminal DC Protection

DC fault characteristics and protection methods

Voltage-source-converter HVDC (VSC-HVDC) has grown quickly, both for connecting offshore wind and for tying asynchronous grids together, and its fault behaviour is even further from AC practice than anything at the inverter terminals discussed above. A DC fault lets current rise extremely fast, because the DC circuit offers little impedance to the transient, and the converter semiconductors can be destroyed within one to two milliseconds if the fault is not cleared (Muniappan, 2021).

Conventional AC breakers are orders of magnitude too slow on that timescale. DC fault protection therefore combines fast semiconductor or hybrid DC breakers, fault-

blocking converter designs that can limit the current at the converter itself, and detection algorithms that must act within a few milliseconds of fault inception. Surveying the field, Muniappan (2021) found no single winning approach, only that practical schemes pair fast detection with either a breaker or a converter for current limiting, the choice turning on the trade-off between cost and reliability.

Multi-terminal coordination and offshore wind

Multi-terminal DC grids, with more than two converter stations on a common DC network, add a further requirement on top of fast detection: the protection must also work out which section is faulted, so that it can isolate that section selectively while power keeps flowing to the rest. Li et al. (2019) reviewed protection for multi-terminal VSC-HVDC grids and noted that fault location and selective isolation are harder in a meshed DC network than in the AC equivalent, precisely because there is no natural current zero crossing and the fault current rises so fast.

Sahebkar Farkhani et al. (2024) surveyed more recent multi-terminal schemes, sorting them by detection speed, selectivity and the capital cost of the DC-breaker technology involved. Their review echoes a theme running through this whole topic: as power-electronic interfaces spread, whether as inverter-based generation or as DC transmission, protection engineering has to reckon with control-system dynamics as much as with circuit physics. Offshore wind is the practical meeting point of the two, since many offshore farms now connect through a dedicated VSC-HVDC link rather than an AC cable, to cut losses over long submarine distances. A fault anywhere along that chain, from the offshore collector system through the HVDC link to the onshore converter, must be located and isolated without needlessly disconnecting healthy parts of the farm, which folds the wind-farm and HVDC protection problems into a single, commercially important case.

Research Gaps

Reading the domain literatures side by side exposes where effort has concentrated and where it has not. Figure 5 sets out that assessment as a matrix of protection domain against research aspect, and four gaps stand out.



Figure 5. Maturity of the literature by protection domain and research aspect. Darker cells mark better-developed areas; pale cells mark gaps. The assessment is the authors' synthesis of the reviewed studies and is intended to guide, not to quantify.

The first gap is validation. The problem characterisation is strong almost everywhere, and adaptive solutions are well developed for transmission distance and microgrid protection, but independent field or real-time-simulation validation thins out quickly, and it is thinnest for wind-farm collector systems and multi-terminal DC. Much of

what is proposed has been demonstrated only in offline simulation against simplified inverter models, which is exactly the setting least able to capture the control-loop effects that cause the trouble.

The second gap is coordination across domains. The interconnection point between a wind farm's collector protection and the transmission protection beyond it is where several studies report coordination slipping, yet it is studied far less than either side in isolation. The offshore-wind-plus-HVDC case, which stacks both problems, is treated in only a handful of papers despite its growing commercial weight.

The third gap is communication dependence. Wide-area and multi-agent schemes lean on low-latency, dependable communication, but the reviewed work rarely quantifies how the protection degrades when that communication is delayed, lost or attacked. For schemes proposed as primary or backup protection, that omission matters, because a communications failure then becomes a protection failure.

The fourth gap is standardisation coverage of the newest installations. IEEE Standard 2800-2022 has begun to bound the fault behaviour of transmission-connected inverter-based resources, but comparable, protection-relevant requirements for microgrids and for multi-terminal DC grids are far less settled, which leaves those domains where transmission was before the standard: dependent on manufacturer-by-manufacturer behaviour.

Economic, Reliability and Standardisation Considerations

Re-coordinating protection is not free. Upgrading or re-setting relays across a transmission system carries engineering cost and requires outage management, and those costs have to be justified by the improvement they buy. Operators have historically been cautious about changing protection philosophy without strong cause, because the consequences of a protection failure are far more serious than those of most other outages, and that caution is part of why the engineering literature on inverter-based protection has grown as quickly as it has: the alternative to studying the problem is discovering it in service.

Standardisation has become the main lever for an industry-wide answer. IEEE Standard 2800-2022 sets interconnection and interoperability requirements for inverter-based resources connecting to transmission systems, including specific requirements for fault-current contribution, ride-through and support for protection coordination, so that behaviour no longer depends on each utility's individual interconnection agreement (IEEE, 2022). Davi et al. (2023) showed the practical worth of this, demonstrating that consistent ride-through and fault-current requirements across interconnections make protection coordination analysis considerably more tractable than in a world where every inverter behaves to its own manufacturer's design.

There is a cost embedded in that predictability: guaranteeing a bounded fault contribution generally means over-sizing the inverter, and that has to be paid for. Even so, the trade looks worthwhile. A known, bounded fault behaviour is what lets protection engineers design with confidence, and it is the precondition for the adaptive and wide-area schemes reviewed here to be engineered reliably rather than tuned by trial and error.

Recommendations for a Renewable-Ready Protection Architecture

Several recommendations follow from the literature reviewed here, offered to utilities and researchers updating protection for a generation mix rich in inverter-based resources.

First, favour current-magnitude-independent principles. Differential protection should be the first choice for lines and feeders at inverter-heavy interconnection points, wherever it is economically justified, because it is largely unaffected by the fault-current reductions at the heart of this review.

Second, treat adaptive, generation-aware settings as a design fundamental rather than an enhancement. On any feeder or line that sees even moderately wide swings in available fault current, a factor of five or more depending on which sources are online, setting logic keyed to generation status should be considered basic rather than optional.

Third, extend wide-area monitoring into a protection resource. Synchrophasor-based wide-area monitoring should be developed beyond situational awareness into an active input to the protection schemes described here, with the communications behind it engineered to a dependability standard that matches its new role.

Fourth, make grid-code compliance non-negotiable. Interconnection to IEEE Standard 2800-2022, or the equivalent regional grid code, should be a firm requirement for every new inverter-based resource, because it is the predictability of the fault contribution that makes the adaptive and wide-area schemes reviewed here safe to engineer.

Fifth, update what engineers are taught. Protection curricula and utility training should cover inverter control behaviour alongside classical short-circuit theory, because the mental model inherited from synchronous machines is now only the starting point for understanding fault behaviour on the present-day grid.

Conclusion

The move from synchronous to inverter-based generation is arguably the deepest change to the physical assumptions of power system protection since the field took its modern shape in the middle of the last century. The reduced, tightly limited fault contribution of wind, solar and battery plant undermines conventional overcurrent and distance protection in now well-understood ways, from distance under-reach to outright overcurrent non-pickup, and at the same time complicates coordination within wind-farm collector systems and among DFIG-connected renewables.

The studies reviewed here each capture part of a field responding to that challenge: accelerated adaptive relay logic, wide-area protection built on synchrophasors, distributed multi-agent coordination, and schemes tailored to microgrids and to voltage-source-converter DC transmission. Standardisation, IEEE Standard 2800-2022 above all, is beginning to give that response a shared technical language. None of these measures repeals the physics of power-electronic fault current, but together they point toward a protection architecture that is maturing to fit a grid whose generation is no longer the grid classical protection theory was written for. The clearest priorities from this synthesis are closing the validation gap between simulation and field performance, and extending to microgrids and multi-terminal DC the kind of bounded, standardised fault behaviour that IEEE 2800 has begun to bring

to transmission.

Conflict of Interest

The authors declare no competing interests.

Funding

This review received no specific grant from any funding agency in the public, commercial or not-for-profit sectors.

References

- Barati, J., Seifossadat, S. G., & Joorabian, M. (2021). A new adaptive coordination scheme of distance relays in DFIG-based wind farm collector lines and transmission line compensated by STATCOM. *International Transactions on Electrical Energy Systems*, 31(12), e13205. <https://doi.org/10.1002/2050-7038.13205>
- Davi, M. J. B. B., Oleskovicz, M., & Lopes, F. V. (2023). Study on IEEE 2800-2022 standard benefits for transmission line protection in the presence of inverter-based resources. *Electric Power Systems Research*, 220, 109304. <https://doi.org/10.1016/j.epsr.2023.109304>
- dos Reis, F. B., Pinto, J. O. C. P., dos Reis, F. S., Issicaba, D., & Rolim, J. G. (2021). Multi-agent dual strategy based adaptive protection for microgrids. *Sustainable Energy, Grids and Networks*, 27, 100501. <https://doi.org/10.1016/j.segan.2021.100501>
- Haddadi, A., Farantatos, E., Kocar, I., & Karaagac, U. (2021). Impact of inverter-based resources on system protection. *Energies*, 14(4), 1050. <https://doi.org/10.3390/en14041050>
- Hussain, N., Khayat, Y., Golestan, S., Nasir, M., Vasquez, J. C., Guerrero, J. M., & Kauhaniemi, K. (2021). AC microgrids protection: A digital coordinated adaptive scheme. *Applied Sciences*, 11(15), 7066. <https://doi.org/10.3390/app11157066>
- IEEE. (2022). *IEEE standard for interconnection and interoperability of inverter-based resources (IBRs) interconnecting with associated transmission electric power systems* (IEEE Std 2800-2022). Institute of Electrical and Electronics Engineers. <https://doi.org/10.1109/IEEESTD.2022.9762253>
- Johansson, H., Xing, Q., Taylor, N., & Wang, X. (2025). Impacts of grid-forming inverters on distance protection. *IET Generation, Transmission & Distribution*, 19(1), e13354. <https://doi.org/10.1049/gtd2.13354>
- Li, B., He, J., Li, Y., & Li, B. (2019). A review of the protection for the multi-terminal VSC-HVDC grid. *Protection and Control of Modern Power Systems*, 4(1), 21. <https://doi.org/10.1186/s41601-019-0136-2>
- Mobashsher, M. M., Abdoos, A. A., Hosseini, S. M., Hashemi, S. M., & Sanaye-Pasand, M. (2023). An accelerated distance protection scheme for the lines connected to inverter-based resources. *IEEE Systems Journal*, 17(4), 6272-6281. <https://doi.org/10.1109/JSYST.2023.3281345>
- Muniappan, M. (2021). A comprehensive review of DC fault protection methods in HVDC transmission systems. *Protection and Control of Modern Power*

Online ISSN

3007-3197

Print ISSN

3007-3189

<http://amresearchreview.com/index.php/Journal/about>

- Systems*, 6(1), 1. <https://doi.org/10.1186/s41601-020-00173-9>
- Peidaee, P., Kalam, A., & Shi, J. (2020). Integration of a heuristic multi-agent protection system into a distribution network interconnected with distributed energy resources. *Energies*, 13(20), 5250. <https://doi.org/10.3390/en13205250>
- Phadke, A. G., & Bi, T. (2018). Phasor measurement units, WAMS, and their applications in protection and control of power systems. *Journal of Modern Power Systems and Clean Energy*, 6(4), 619-629. <https://doi.org/10.1007/s40565-018-0423-3>
- Quispe, J. C., & Orduña, E. (2022). Transmission line protection challenges influenced by inverter-based resources: A review. *Protection and Control of Modern Power Systems*, 7(1), 28. <https://doi.org/10.1186/s41601-022-00249-8>
- Rezaei Jegarluei, M., Aristidou, P., & Azizi, S. (2023). Wide-area backup protection against asymmetrical faults in the presence of renewable energy sources. *International Journal of Electrical Power & Energy Systems*, 144, 108528. <https://doi.org/10.1016/j.ijepes.2022.108528>
- Sahebkar Farkhani, J., Celik, O., Ma, K., Bak, C. L., & Chen, Z. (2024). A comprehensive review of potential protection methods for VSC multi-terminal HVDC systems. *Renewable and Sustainable Energy Reviews*, 192, 114280. <https://doi.org/10.1016/j.rser.2024.114280>
- Shahbazzadeh, R., Tarafdar Hagh, M., & Ghanizadeh, R. (2025). Comprehensive analysis of challenges and two practical methods for protective coordination of distance relays in transmission lines connected to DFIG-based wind farms. *Scientific Reports*, 15(1), 17374. <https://doi.org/10.1038/s41598-025-01728-2>
- Yoosefian, D., Askarian-Abyaneh, H., Kheshti, M., Li, Q., & Terzija, V. (2023). Fault ride-through constrained protection scheme for distribution networks with DFIG-based wind parks. *Electric Power Systems Research*, 215, 108973. <https://doi.org/10.1016/j.epsr.2022.108973>